


PRFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

NO. 1070

DATE : 20/08/2025

It is certified that an inspection team headed by (SUB DIVISIONAL ENGINEER) from WATER SUPPLY AND SANITATION, SUB DIVISION, TARN TARAN inspected the AKAL ACADEMY Teja Singh Wala Tarn Taran (PB) on 19.08.2025 and found that the AKAL ACADEMY Teja Singh Wala Tarn Taran has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T Govt.

The above valid for a period of 18.08.2026


Sub Divisional Engineer
Water Supply & Sanitation
Signature with Seal : Sub Division, Tarn Taran
Designation : SUB DIVISIONAL ENGINEER

AKAL ACADEMY Teja Singh Wala
Tarn Taran

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtl1@gmail.com

To,

AKAL ACADEMY
Teja Singh wala , Tarn Taran


No.: DWTLTT/2526/00164 Dated : 26/07/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 2030/22 Dated: 15/07/2025

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 25/07/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtl1@gmail.com



TC-14756

TEST REPORT

Name & Address of Customer : AKAL ACADEMY Teja Singh wala , Tarn Taran		Customer Reference No.	No : 2030/22 Dated : 15/07/2025
		Sample Submitted by	Mr Daljit Singh
		Date of Sample Receipt	25/07/2025
		Analysis Starting Date	25/07/2025
		Analysis completion Date	26/07/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC14756250000263F	Sample Type :	Water
Test Report No.:	DWTLTT/2526/00164	Date of Issue :	26/07/2025
Registration no.:	DWTLTT/REG2526/00620	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	2000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / NA
Village :	Kot Jaspal	Habitation :	Kot Jaspal
Block:	Tarn Taran	District :	Tarn Taran
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.30@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	263	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	240	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	208	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	56.11	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	16.52	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	15.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr.Mohammad Naushad Alam
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran

----- End of the Test Report -----

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtl1@gmail.com



TC-14756

TEST REPORT

Name & Address of Customer : AKAL ACADEMY Teja Singh wala , Tarn Taran		Customer Reference No.	No : 2030/22 Dated : 15/07/2025
		Sample Submitted by	Mr Daljit Singh
		Date of Sample Receipt	25/07/2025
		Analysis Starting Date	25/07/2025
		Analysis completion Date	26/07/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC14756250000263F	Sample Type :	Treated Water
Test Report No.:	DWTLTT/2526/00164	Date of Issue :	26/07/2025
Registration no.:	DWTLTT/REG2526/00621	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	2000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / NA
Village :	Kot Jaspat	Habitation :	Kot Jaspat
Block:	Tarn Taran	District :	Tarn Taran
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.79@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	263	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	240	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	208	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	56.11	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	16.52	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	15.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr.Mohammad Naushad Alam
Quality Manager
Authorized Signatory
For,District Water Testing Laboratory
Tarn Taran

----- End of the Test Report -----